

Zertifikat Certificate



Zertifikat Nr. *Certificate No.*
R 60093707

Blatt *Page*
0001

| <i>Ihr Zeichen Client Reference</i> | <i>Unser Zeichen Our Reference</i> | <i>Ausstellungsdatum</i> | <i>Date of Issue</i> |
|-------------------------------------|------------------------------------|--------------------------|----------------------|
| | 0001-- 27115012 001 | 29.04.2014 | (day/mo/yr) |

| <i>Genehmigungsinhaber License Holder</i> | <i>Fertigungsstätte Manufacturing Plant</i> |
|---|---|
| ERSE KABLO İMAL. SAN.ve TİC.LTD.ŞTİ. ORTAKÖY SAN.BÖL. 152 ADA 13.PARSEL SELİMPAŞA-SİLİVRİ-İSTANBUL Türkiye | ERSE KABLO İMAL. SAN.ve TİC.LTD.ŞTİ. ORTAKÖY SAN.BÖL. 152 ADA 13.PARSEL SELİMPAŞA-SİLİVRİ-İSTANBUL Türkiye |

Prüfzeichen Test Mark

Geprüft nach *Tested acc. to*
2 PFG 1169/08.07



Zertifiziertes Produkt (Geräteidentifikation)
Certified Product (Product Identification)

Lizenzentgelte - Einheit
License Fee - Unit

PV-Cables

| | | |
|-------------------------|--|----|
| Code designation: | PV1-F | 11 |
| Cross section: | 1,5mm ² , 2,5mm ² , 4,0mm ² , 6,0mm ² 10,0mm ² , 16,0mm ² , 25mm ² , 35mm ² 50,0 mm ² , 70,0 mm ² , 95,0 mm ² , 120,0 mm ² , 150,0 mm ² , 185 mm ² 240,0 mm ² | 15 |
| Rated voltage: | 0,6/1 kV AC; 1,8 kV DC | |
| Ambient temperature: | -40°C to 90°C | |
| Max. Conductor temp.: | +120°C (for 20.000 h) | |
| Material of insulation: | Halogen free cross-linked compound | |
| Material of sheath: | Halogen free cross-linked compound | |
| Color of insulation: | White | |
| Color of sheath: | Black, Red, Blue | |

26

Dem Zertifikat liegt unsere Prüf- und Zertifizierungsordnung zugrunde und es bestätigt die Konformität des Produktes mit den oben genannten Standards und Prüfgrundlagen. Zusätzliche Anforderungen in Ländern, in denen das Produkt in Verkehr gebracht werden soll, müssen zusätzlich betrachtet werden. Die Herstellung des zertifizierten Produktes wird überwacht.
This certificate is based on our Testing and Certification Regulation and states the conformity of the product with the standards and testing requirements as indicated above. Any additional requirements in countries where the product is going to be marketed have to be considered additionally. The manufacturing of the certified product is subject to surveillance.

TÜV Rheinland LGA Products GmbH, Tillystraße 2, 90431 Nürnberg
Tel.: +49 221 806-1371 e-mail: cert-validity@de.tuv.com
Fax: +49 221 806-3935 http://www.tuv.com/safety

Zertifizierungsstelle

Sahure Oralalp